

Many local authorities, consultants, engineers and contractors specify and use our fibreglass insulated F30 tanks, secure in the knowledge that both they and their clients are in safe hands, and helping them meet their health and safety obligations. In order to comply with health and safety directives, which states that water, that may be consumed by humans, must be held in Insulated tanks, and that all tanks must meet the following criteria.

- Factory insulated with CFC Free Foam on all sides
- Fibreglass in construction
- · Lids must be sealed and insulated
- Suitable for Potable (drinking) water
- Tanks must have screened inlet and overflows
- Tanks to be insulated to reduce the risk of freezing in winter and assist in keeping the water temperature low in summer time
- Have suitable fibreglass condensation trays, plumbed to an overflow

Also from Tricel (Killarney)

- · Sectional water storage tanks
- Custom moulding, access chambers, safety products
- · Underground and overground storage tanks
- Tricel Novo wastewater treatment systems
- Kiosks
- Insulated housings
- Metering cabinets (electrical and gas)

		Non - Insulated			Insulated		
Litres	Gallons	Length	Width	Height	Length	Width	Height
45	10	495	370	345	495	370	345
114	25	1180	505	340	1210	540	350
182	40	1030	510	457	1055	550	480
182	40	670	530	565	700	575	575
227	50	1142	500	465	1240	535	480
318	70	1230	575	584	1240	585	585
454	100	1425	725	585	1448	737	599
454	100	1040	761	766	1040	761	766
682	150	1630	1045	535	1725	1120	535
909	200	1620	1040	685	1725	1120	690
909	200	1243	964	969	1243	964	969
1136	250	1670	1075	845	1725	1120	845
1363	300	1665	1235	845	1690	1270	935
1818	400	2520	1290	610	2520	1390	775
2275	500	1880	1380	1125	1910	1405	1230
2700	600	_	_	_	2030	1500	1290
3637	800	2665	1775	965	2715	1800	1015
4546	1000	2665	1715	1245	2665	1715	1320

Please note: Insulation slows down, but does not prevent heat loss or heat gain, over protracted periods. Additional information is available in BS 7491 & BS 6700.



