


SECTIONAL TANK

CLEARANCE REQUIREMENTS



TRICEL
GENERATIONS OF INNOVATION

Manufacturing Tanks Since 1973



For more information contact us today at:
watersales@trichel.ie or www.trichelwater.ie

ASSOCIATION OF
TANK AND CISTERN
MANUFACTURERS
SETTING THE STANDARDS



Sectional water tank clearance requirements



Internally flanged base tanks

- Headroom clearance to be a minimum of 750mm to allow the hinged access hatch to fully function. This can be reduced to 500mm in accordance with WRAS guidelines where a "lift off access hatch" is fitted. It's important to allow sufficient space for a person to gain safe access to the tank for future maintenance.
- Where hooped external ladders and guardrail are fitted, a height clearance of 1200mm above the tank is required.
- Around the tank:
 - A minimum of 500mm from internal tank dimensions is required for tanks up to 2m high.
 - Tanks at 2.5 to 3m high, a clearance of 800mm from the internal tank dimensions is required.
 - Tanks at 3.5 to 4m high ideally require a minimum of 1m clearance from the internal tank dimensions.

Externally flanged base tanks

- Headroom clearance to be a minimum of 750mm to allow the hinged access hatch to fully function. This can be reduced to 500mm in accordance with WRAS guidelines where a "lift off access hatch" is fitted. It's important to allow sufficient space for a person to gain safe access to the tank for future maintenance.
- Where hooped external ladders and guardrail are fitted, a height clearance of 1200mm above the tank is required.
- A clearance space of 600mm is required below the tank in accordance with BS EN 806
- Around the tank:
 - A minimum of 500mm from internal tank dimension is required for tanks up to 1.5m high.
 - Tanks at 2m to 2.5m high, a clearance of 800mm from the internal tank dimensions is required.
 - Tanks at 3m to 4m high ideally require a minimum of 1m clearance from the internal tank dimensions.

T.I.F tank (Hot Press and HLU)

- Headroom clearance to be a minimum of 750mm to allow the hinged access hatch to fully function. This can be reduced to 500mm in accordance with WRAS guidelines where a "lift off access hatch" is fitted. It's important to allow sufficient space for a person to gain safe access to the tank for future maintenance.
- Where hooped external ladders and guardrail are fitted, a height clearance of 1200mm above the tank is required. 1056315 Rev 0 Sept. 19
- A clearance of 50mm from external tank dimension is required on 3 sides of the tank and a minimum of 500mm from external tank dimensions is required on the side with connections and pipework.

1056315 Rev. 1



Please note: Insulation slows down, but does not prevent heat loss or heat gain, over protracted periods.
Additional information is available in BS 7491 & BS 6700.

Tricel (Killarney) Unlimited Company, Ballyspillane Industrial Estate, Killarney, Co. Kerry, Ireland.

Tel: +353 (0) 64 6632421 | Email: watersales@tricel.ie | www.tricelwater.ie

In accordance with Tricel's normal policy of product development these specifications are subject to change without notice.